

## AGRO combination conduit glands Progress® nickel-plated brass increased safety



### AGRO combination conduit glands Progress® nickel-plated brass increased safety Ex e II

#### Type approval: Progress MS Kombi EX

- One-piece sealing insert
- not overall length insulated

|                       |                                                   |
|-----------------------|---------------------------------------------------|
| <b>Article no:</b>    | <b>EX1700.25.27.125</b>                           |
| EAN:                  | 7611614252933                                     |
| Material              | Nickel-plated brass                               |
| Seal                  | TPE                                               |
| O-ring                | FPM                                               |
| Operation temperature | -60°C / +100°C                                    |
| Protection class      | IP 66 / IP 68                                     |
| Test standard         | IEC EN 60079-0 / IEC EN 60079-7 / IEC EN 60079-31 |
| Gas                   | II 2G Ex eb IIC Gb                                |
| Dust                  | II 2D Ex tb IIIC Db                               |
| Zone                  | Gas 1 and 2 / dust 21 and 22                      |
| Certificate           | SEV 15 ATEX 0152X                                 |
| IECEx Certificate     | IECEx SEV 15.0019X                                |
| CCC Certificate       | CCC 2022322313004811                              |
| Entry thread          | M25x1.5                                           |
| Outer diameter        | 27 mm                                             |
| Clamping range min.   | 10.5 mm                                           |
| Clamping range max.   | 12.5 mm                                           |
| Wrench size           | 30/36 mm                                          |
| Dimension H           | 50 mm                                             |
| Thread length L       | 7 mm                                              |
| Dispatch              | 25                                                |

Long entry thread available on request

Depending on the type of conduit, the stabilising bush must be ordered separately.

Warning: Only metallic conduits or conduits with metallic braiding may be applied !